TAZEWELL COUNTY REGIONAL OFFICE OF EDUCATION #53 Health/Life Safety Verification Form

Name of School	
I hereby certify that each item in this checklist has been verified and the responses	checked are correct.
Principal's/Designee Signature	Date

Please have required inspection documentation (*) available for review on the day of inspection

Item	Yes	No	N/A
Tornado and fire drill evacuation instructions posted in student-occupied areas.			
•			
Shop, Science, and Art Safety Glasses used by students as required			
All art materials are non-toxic (K-6) or meet labeling standards (7-12)			
Flammable/combustible materials are properly labeled and in approved storage			
*Bleacher Inspections - required annually by "qualified" inspector – could be maintenance person Date			
*Elevator/Lift Inspection Certificate (in office or elevator) Expiration Date			
* Boiler Inspection Certificates (in boiler rooms) Expiration Date			
*Fire Alarm System Inspection – Date (provide copy)			
*Sprinkler System Inspection – Date (provide copy)			
*Range Exhaust System Inspection and cleaning (by employee) once per year Date			
*Kitchen Extinguishing System Inspection Date			
*Flameproof Stage Curtains - Certificate/Tag or Letter of Verification			
*Schedule of Monthly Tests of Emergency Lights (by employees) *Date of system shut-down for 60 minutes			
*Monthly record of carbon-monoxide inspection report			
*Safety Reference Plan in <u>school</u> office, not district office Footprint of building indicating gas, electrical, water, etc not just a floor plan.			
*Safety Drill Report Form Required for items below (Previous year)			
Crisis Plan Review Date(By June 30 of previous year)			
Fire Drill #1. Date (Please note which included Fire Drill #2. Date Fire Department)			
Fire Drill #3. Date			
Severe Weather Drill Date (all students)			
Bus Evacuation Drill Date (all students) Law Enforcement Drill Date (Police participation)			
(Must be in first 90 days of school year with students present)			

^{*} Documentation required for these items.